

# WELLCO

Pressure Controls Ltd.

## SETTING INSTRUCTIONS

### MODEL 01-PC DUAL SEAL AUTO RESET 2" C/W TEST PORT TRIM



TO CHANGE PRESSURE SETTING:

1. LOOSEN THE SMALL SLOTTED SET SCREW
2. UTILIZING EITHER A STRAP WRENCH, PIPEWRENCH OR BY HAND ROTATE THE PRESSURE ADJUSTMENT COLLAR CLOCKWISE TO INCREASE PRESSURE; COUNTER CLOCKWISE TO DECREASE PRESSURE. EACH ½ TURN IS APPROXIMATELY 50 psi
3. TIGHTEN THE SLOTTED SET SCREW.

INSTALL CONTROL WITH EITHER PIPEWRENCH OR FLAT WRENCH ONTO A LOCKING BALL VALVE TO UTILIZE THE TEST PORTS ON THE TRIM

FOR FURTHER ASSISTANCE CALL 1-866-4WELLCO

WWW.WELLCOPRESSURECONTROLS.CA